



Pete Ricketts, Governor

Fire Protection of Cooking Operations

Cooking equipment shall not be required to be protected by a fire suppression system or an exhaust hood when **ALL** of the following requirements are met, each box is marked, and this form is signed and dated by all parties:

- Portable fire extinguishers shall be provided in the vicinity of the cooking equipment in accordance with NFPA 10.
- Readily visible permanent signage shall be provided at the cooking equipment stating: "NO FRYING PERMITTED"
- Food prepared in this facility shall not be sold and is therefore not considered Commercial Cooking.

OR Cooking equipment located within an educational classroom, or classroom setting (consumer science) shall not be required to be protected by a fire suppression system or an exhaust hood when **ALL** of the following requirements are met, each box is marked, and this form is signed and dated by all parties:

- Portable fire extinguishers shall be provided in the vicinity of the cooking equipment in accordance with NFPA 10.
- Cooking is supervised at all times.
- A supervised fire sprinkler system protects the room where cooking is conducted.

This document applies to commercial or residential cooking equipment and includes ranges, induction appliances and portable cooking equipment such as hot plates.

By signing this document, you agree to the above conditions. Any changes to the terms agreed upon must be approved by the authority having jurisdiction.

Name of Facility	Facility Email
Owner/Operator	<div style="display: flex; justify-content: space-between;"> X Date </div>
State Fire Marshal Representative	<div style="display: flex; justify-content: space-between;"> X Date </div>
	<div style="display: flex; justify-content: space-between;"> Owner/Operator Signature Date </div>
	<div style="display: flex; justify-content: space-between;"> Representative Signature Date </div>

RE: National Fire Protection Association (NFPA) 96, 1.2

- | | | | | |
|---|---|---|---|--|
| <input type="checkbox"/> MAIN / DISTRICT A / BOILERS / PLANS INVESTIGATIONS / FIRE PREVENTION
246 South 14th Street
Lincoln, NE 68508
(402) 471-2027 | <input type="checkbox"/> FUELS DIVISION
<input type="checkbox"/> FLST <input type="checkbox"/> PIPELINE SAFETY
246 South 14 th Street
Lincoln, NE 68508
(402) 471-9465 | <input type="checkbox"/> DISTRICT B/C OFFICE
438 West Market
Albion, NE 68620
(402) 395-2164 | <input type="checkbox"/> ELEVATOR DIVISION
1313 Farnam Street, Room 233
Omaha, NE 68102
(402) 595-3184 | <input type="checkbox"/> TRAINING DIVISION
3347 W Capital Ave
Grand Island, NE 68803
(308) 385-6892 |
|---|---|---|---|--|

